















		New Power Logic Meters			
Select New Meter → Select Existing Meter being Replaced ↓		 ION 7300 series	 ION 8500 / 8600	 ION 700 / 800	 ION 6200
Existing GE Series Meters	GE DS-63,DS-65,D66,ES, EV GE KV, KV2, KV2C,M-90  SUSI CASE "GS"	 SWDGS_	 SWRGS_	 SWDGS_	 SWDGS_
	 GE EPM 5100	 SWDGS_-EPM	 SWRGS_-EPM	 SWDGS_-EPM	 SWDGS_-EPM
	GE M-90R (Deep GS)  SUSI Case "GSR"	 SWDGSR_	 SWRGSR_	 SWDGSR_	 SWDGSR_
	GE DS-64 SUSI Case "GL"  SUSI Case "GL"	 SWDGL_	 SWRGL_	 SWDGL_	 SWDGL_
	GE M-90R (Deep "GL") SUSI Case "GLR"  SUSI Case "GLR"	 SWDGLR_	 SWRGLR_	 SWDGLR_	 SWDGLR_

Notes: 1. The “_” in the SUSI part number is to be replaced with a 5, 6 or 9 for a 2, 2 1/2 and 3 element meters respectively. 600-2003-00-C
 2. All SUSI SWD series products have the option “-M” for mounting and wiring the meter into the SUSI adapter.

New Power Logic Meters

Select New Meter →

Select Existing Meter being Replaced ↓



ION 7300 series

ION 8500 / 8600

ION 700 / 800

ION 6200

Existing GE Series Meters

GE DS-38

SUSI # "G38"

GE DS-39

SUSI # "G39"

GE DS-43

SUSI # "G43"

GE DS-44



























SUSI Case "GX"

Notes: 1. The “_” in the SUSI part number is to be replaced with a 5, 6 or 9 for a 2, 2 1/2 and 3 element meters respectively. 600-2003-00-C
 2. All SUSI SWD series products have the option “-M” for mounting and wiring the meter into the SUSI adapter.



Schneider Electric/SUSI Adapters Selection Guide



		New Power Logic Meters			
Select New Meter → Select Existing Meter being Replaced ↓		 ION 7300 series	 ION 8500 / 8600	 ION 700 / 800	 ION 6200
Existing GE Series Meters	GS DS-53; DS-55 (Semi-Draw-Out)  SUSI case "G53"	 SWDG53_	 SWRG53_	 SWDG53_	 SWDG53_
	GE DS-54 (Semi-drawout)  SUSI case "G54"	 SWDG54_	 SWRG54_	 SWDG54_	 SWDG54_
	GE DS-67 (Two 2-element meters); SUSI case "G67"	 SWDG67	Two  SWBXS5	 SWDG67	 SWDG67
	GE DS-69 (Two 2 1/2 element meters); SUSI case "G67"	 SWDG69	Two  SWBXS6	 SWDG69	 SWDG69
	Westinghouse/ABB Series CB, D2B D4B, D5B Alpha, L+G 2510, PSI FT-21 case SUSI case "WS"	 SWDWS_	 SWRWS_	 SWDWS_	 SWDWS_

Notes: 1. The “_” in the SUSI part number is to be replaced with a 5, 6 or 9 for a 2, 2 1/2 and 3 element meters respectively. 600-2003-00-C
 2. All SUSI SWD series products have the option “-M” for mounting and wiring the meter into the SUSI adapter.



Schneider Electric/SUSI Adapters Selection Guide



New Power Logic Meters

<p>Select New Meter</p> <p>Select Existing Meter being Replaced</p> <p>↓</p>	 <p>ION 7300 series</p>	 <p>ION 8500 / 8600</p>	 <p>ION 700 / 800</p>	 <p>ION 6200</p>
--	---	---	---	--

Existing Westinghouse/ABB Series Meters	<p>Westinghouse ABB Series CB,D2B, D4B D5B;Alpha, L+G 2510, PSI</p>  <p>FT-32 case SUSI Case "WM"</p>	 <p>SWDWM_</p>	 <p>SWRWM_</p>	 <p>SWDWM_</p>	 <p>SWDWM_</p>
	<p>Westinghouse ABB Series CB, D2B, D4B, D5B; Alpha, L+G 2510, PSI</p>  <p>FT-31 case SUSI Case "WL"</p>	 <p>SWDWL_</p>	 <p>SWRWL_</p>	 <p>SWDWL_</p>	 <p>SWDWL_</p>
	<p>Westinghouse Series "Old" CB, 2 screws on cover</p>  <p>SUSI "WCB"</p>	 <p>SWDWCB_</p>	 <p>SWAAF_ or SWBXS_</p>	 <p>SWDWCB_</p>	 <p>SWDWCB_</p>
	<p>Westinghouse Series D_B-32F Two 2 1/2 element</p>  <p>FT-32 Case SUSI # "W32"</p>	 <p>SWDW326</p>	 <p>Two SWBXS6</p>	 <p>SWDW326</p>	 <p>SWDW326</p>
	<p>Westinghouse Series D_B-38F Two 2 element</p>  <p>FT-32 Case SUSI # "W38"</p>	 <p>SWDW385</p>	 <p>Two SWBXS5</p>	 <p>SWDW385</p>	 <p>SWDW385</p>

Notes: 1. The "_" in the SUSI part number is to be replaced with a 5, 6 or 9 for a 2, 2 1/2 and 3 element meters respectively. 600-2003-00-C
 2. All SUSI SWD series products have the option "-M" for mounting and wiring the meter into the SUSI adapter.



Schneider Electric/SUSI Adapters Selection Guide



New Power Logic Meters

<p>Select New Meter →</p> <p>Select Existing Meter being Replaced ↓</p>	 <p>ION 7300 series</p>	 <p>ION 8500 / 8600</p>	 <p>ION 700 / 800</p>	 <p>ION 6200</p>
---	---	---	---	--








<p style="writing-mode: vertical-rl; transform: rotate(180deg);">Existing "Basler" Style Meters</p> <p>JEM10, JEMSTAR-Trans-data; SUSI # "TS"</p> 	 <p>SWDTS_</p>	 <p>SWRTS_</p>	 <p>SWDTS_</p>	 <p>SWDTS_</p>
	 <p>SWDJL_</p>	 <p>SWRJL_ or SWIJL_</p>	 <p>SWDJL_</p>	 <p>SWDJL_</p>
<p style="writing-mode: vertical-rl; transform: rotate(180deg);">Existing Non-case Meters</p>  <p>PM/GE/Siemens 3700/4700</p>	 <p>SWF3710</p>	 <p>SWFXS_</p>	 <p>SWF3710</p>	 <p>SWF3710</p>
	 <p>Various Plates</p>	 <p>SWBXSL</p>	 <p>Various Plates</p>	 <p>Various Plates</p>
<p style="writing-mode: vertical-rl; transform: rotate(180deg);">All Others</p>  <p>All other panel meters</p>	 <p>Various Plates</p>	 <p>SWAAF_ or SWBXS_</p>	 <p>Various Plates</p>	 <p>Various Plates</p>

Notes: 1. The “_” in the SUSI part number is to be replaced with a 5, 6 or 9 for a 2, 2 1/2 and 3 element meters respectively.
 2. All SUSI SWD series products have the option “-M” for mounting and wiring the meter into the SUSI adapter. 600-2003-00-C



Schneider Electric/SUSI Adapters Selection Guide New Installations



<p>New Socket Meter →</p> <p>Select SUSI Adapters Product</p> <p>↓</p>	 <p>ION8500/8600/8650</p>
 <p>Flush Mount SWAAF_</p>	
 <p>Surface Mount SWBXS_</p>	
 <p>Surface Mount SWFXS_</p>	

- Notes: 1. The “_” in the SUSI part number is to be replaced with a 5, 6 or 9 for a 2, 2 1/2 and 3 element meters respectively.
2. All SUSI SWD series products have the option “-M” for mounting and wiring the meter into the SUSI adapter.

600-2003-00-C